

UK DECLARATION OF CONFORMITY

As manufacturer:

Imtex Controls Limited
Unit 4, 10th Avenue, Deeside Point,
Zone 3 Deeside Industrial Park
Flintshire, CH5 2UA, U.K.

Hereby declares that the following product(s): **Type DQ Valve Position Monitor**

is / are in conformity with the following directives and standards :

- **The UKEX Regulations UKSI 2016:1107 (as amended)**

Conformity has been demonstrated with reference to the following documentation :

- **UKEX Type examination certificate CSAE 21UKEX1450X**
- **Quality Assurance Notification CSAE 23 UKQAN 0111**
- **ISO 9001:2015 Quality System Certificate 031486 (Sira)**

Compliance with the following harmonised standards :

- **EN IEC 60079-0:2018**
- **EN60079-7:2015 + A1:2018**
- **EN60079-18:2015 + A1:2017**
- **EN60079-31:2014**

Additional information:

UKEX coding: II 2 G D Ex eb mb IIC T4/T6 Gb
Ex tb IIIC T100°C/T85°C Db

Limitations on use: See certificate

Name and address of the Notifying Bodies:

<u>Product</u>	<u>Quality System</u>
CSA Group Testing UK Ltd Unit 6, Industrial Park Hawarden, Deeside CH5 3US, United Kingdom Notified Body Identification Number : 0518	CSA Group Testing UK Ltd Unit 6, Industrial Park Hawarden, Deeside CH5 3US, United Kingdom Notified Body Identification Number : 0518

This declaration is issued in compliance with the essential protection requirements of:

Electromagnetic Compatibility Regulations 2016 (SI 2016 No 1091, as amended)

Signed :



Authorised Person : Paul Turner – Engineering Manager

Date : 16/3/2022