

UK DECLARATION OF CONFORMITY

As manufacturer:

Imtex Controls Limited
Unit 4, 10th Avenue, Deeside Point
Zone 3, Deeside Industrial Park
Flintshire, CH5 2UA, U.K.

Hereby declares that the following product(s): **Type SLR Valve Position Monitor**

is / are in conformity with the following directives and standards:

- **The UKEX Regulations UKSI 2016:1107 (as amended)**

Conformity has been demonstrated with reference to the following documentation:

- **UKEX Type examination certificate CSAE 21UKEX2452X**
- **Quality Assurance Notification CSAE 23 UKQAN 0111**
- **ISO 9001:2015 Quality System Certificate 031486 (Sira)**

Compliance has been verified with the following harmonised standards demonstrated:

- **EN IEC 60079-0:2018**
- **EN 60079-11:2012**

Additional information:

UKEX coding:

II 2 G D Ex ia IIC T* Gb

Ex ia IIIC T₍₂₀₀₎°C Db (Group III Simple apparatus)

Ex ia IIIC T_(T)*°C Db (Group III Certified Equipment)

(* - The temperature class, max surface temperatures for dust and ambient temperature range that is appropriate depends on devices used in the construction of the SLR Valve Position Monitor, refer to Condition of Manufacture)

Conditions on use: See certificate

Name and address of the Notifying Bodies:

<u>Product</u>	<u>Quality System</u>
CSA Group Testing UK Ltd Unit 6, Industrial Park Hawarden, Deeside CH5 3US, United Kingdom Notified Body Identification Number : 0518	CSA Group Testing UK Ltd Unit 6, Industrial Park Hawarden, Deeside CH5 3US, United Kingdom Notified Body Identification Number : 0518

This declaration is issued in compliance with the essential protection requirements of:

- **Electromagnetic Compatibility Regulations 2016 (SI 2016 No 1091, as amended)**

Signed:



Authorised Person: Paul J Turner - Engineering Manager - Date : 14/2/2023