

DECLARATION OF CONFORMITY

As manufacturer:

Imtex Controls Limited
Unit 4, 10th Avenue, Deeside Point
Zone 3, Deeside Industrial Park
Flintshire, CH5 2UA, U.K.

Hereby declares that the following product(s) : **Type V Valve Controller**

is / are in conformity with the following directives and standards :

- **The UKEX Regulations SI 2016:1107 (as amended)**

Conformity has been demonstrated with reference to the following documentation :

- **UKEX Type examination certificate EMA22UKEX0015X**
- **Quality Assurance Notification CSAE 23 UKQAN 0111**
- **ISO 9001:2015 Quality System Certificate 031486 (Sira)**

Compliance with the following harmonised standards :

- **EN IEC 60079-0:2018**
- **EN60079-1:2014**
- **EN60079-11:2012**
- **EN60079-31:2014**

Additional information:

UKCA coding: II 2 G D Ex db [ja] IIC T4/T6 Gb
Ex tb IIIC T135°C/T85°C Db

Limitations on use: See certificate

Name and address of the Notifying Bodies :

Issuance of UKEX Compliance Certificate Element Material Technology Unit 1, Pendle Place, Skelmersdale, West Lancashire, WN8 9PN, United Kingdom	Issuance of Quality Assurance Notification CSA Group Testing UK Ltd Unit 6, Industrial Park Hawarden, Deeside CH5 3US, United Kingdom
Notified Body Identification Number : 0891	Notified Body Identification Number : 0518

This declaration is issued in compliance with the essential protection requirements of:

Electromagnetic Compatibility Regulations 2016 (SI 2016 No 1091, as amended)

Signed:



Authorised Person: Paul Turner – Engineering Manager

Date : 17.1.23