



1 **EU-TYPE EXAMINATION CERTIFICATE**

2 Equipment intended for use in Potentially Explosive Atmospheres Directive 2014/34/EU

3 Certificate Number: **Sira 08ATEX1266X** **Issue 5**

4 Equipment: **Valve Position Monitor**

5 Applicant: **Imtex Controls Limited**

6 Address: Unit 4 Deeside Point  
10th Avenue Zone 3 Deeside Industrial Park  
Flintshire CH5 2UA  
UK

7 This equipment and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

8 CSA Group Netherlands B.V., Notified Body Number 2813 in accordance with Articles 17 and 21 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in the confidential reports listed in Section 14.2.

9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the schedule to this certificate, has been assured by compliance with the following documents:

EN 60079-0:2006

EN 60079-1:2007

EN 60079-31:2009

10 If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to Specific Conditions of Use identified in the schedule to this certificate.

11 This EU-Type Examination Certificate relates only to the design and construction of the specified equipment. If applicable, further requirements of this Directive apply to the manufacture and supply of this equipment.

12 The marking of the equipment shall include the following:



II 2 G D

Ex d IIC T\* Gb

Ex tb IIIC T\*°C Db IP6X

(Tamb -\*°C to +\*°C)

\* Refer to Description of Equipment for specific marking

Project Number 1448

Signed: 

Title: Director of Operations

This certificate and its schedules may only be reproduced in its entirety and without change

**CSA Group Netherlands B.V.**  
Utrechtseweg 310,  
6812 AR, Arnhem,  
Netherlands



## SCHEDULE

### EU-TYPE EXAMINATION CERTIFICATE

Sira 08ATEX1266X  
Issue 5

#### 13 DESCRIPTION OF EQUIPMENT

The IQxx Series Valve Position Indicator is constructed from cast stainless steel and consists of a main enclosure base and threaded lid cover, providing a flameproof threaded joint. The cover is secured in place by an M4 x 0.7 set screw through the base flange. The base has provision for up to three cable entries that are used with suitably certified cable glands allowing the equipment to be connected to an external electrical power source. Unused cable entries are closed off with suitably certified, blanking devices. A drive shaft passing through the base creates a flameproof cylindrical joint. The drive shaft, which rotates intermittently at less than 1 m/s through a maximum of 180°, operates various internal switch configurations. The drive shaft also operates a polycarbonate visual position indicator, which is secured externally to the under side of the base and shows the status of the valve.

Product Nomenclature IQ-a-b-c-d-e-f	
a)	Alternative internal switches
b)	Enclosure material
c)	Entry thread types
d)	Output drive shaft type
e)	Indicator
f)	Feature

Equipment markings and electrical ratings					
Type	Marking for gas	Marking for dust	Ambient temp. range	Max. power dissipation	Cable entry temp. rise
Monitor with tall cover	Ex d IIC T6 Gb	Ex tb IIIC T85°C Db IP6X	Ta -40°C to +40°C	18.63 W	25.8°C
	Ex d IIC T6 Gb	Ex tb IIIC T85°C Db IP6X	Ta -40°C to +60°C	8.13 W	12.8°C
	Ex d IIC T4 Gb	Ex tb IIIC T135°C Db IP6X	Ta -15°C to +85°C	24.45 W	32.2°C
Monitor with short cover	Ex d IIC T6 Gb	Ex tb IIIC T85°C Db IP6X	Ta -40°C to +40°C	12.42 W	25.5°C
	Ex d IIC T6 Gb	Ex tb IIIC T85°C Db IP6X	Ta -40°C to +60°C	6.12 W	12.7°C
	Ex d IIC T4 Gb	Ex tb IIIC T135°C Db IP6X	Ta -15°C to +85°C	15.22 W	30.7°C

**Variation 1** - This variation introduced the following change:

- i. The introduction of 6 alternative VCT module options to the interior of the valve position monitor.

**Variation 2** - This variation introduced the following change:

- i. The use of alternative 3 to 6 reed switches, rated 0.15 A at 125 V a.c. or 30 V d.c. was endorsed.

**Variation 3** - This variation introduced the following changes:

- i. The maximum ambient temperature was reased from +80° to +85°C for T4 and the T135 ratings, consequently, the table in the description and Condition of Certification clause 17.4 were amended.
- ii. Following appropriate assessment to demonstrate compliance with the latest technical knowledge, the documents previously listed in section 9, EN 61241-0:2006 and EN 61241-1:2004, were replaced by EN 60079-31:2009.



## SCHEDULE

### EU-TYPE EXAMINATION CERTIFICATE

Sira 08ATEX1266X  
Issue 5

iii. The Applicant's address was changed:

From:  
Unit 5A Valley Industries  
Hadlow Road  
Tonbridge  
Kent TN11 0AH  
UK

To:  
Unit 4 Deeside Point  
10th Avenue Zone 3  
Deeside Industrial Park  
Flintshire CH5 2UA  
UK

**Variation 4** - This variation introduced the following changes:

- i. The removal of the following material notes from the housing and the cover variant drawings. 'DIN1690 Part10 Cast Stainless Steel 316SS Grade' and 'exceeds the quality of 150 (ISO 185)'
- ii. The introduction of alternative stainless steel grades for the housing and the cover variants. Therefore becoming:  
IQ-a-**b**-c-d-e-f  
Where **b** designates enclosure material of manufacture:  
S CF8M or  
CF3M or alternative Cast Austenitic Stainless Steel grades  
D CD3MN or alternative Cast Duplex Stainless Steel grades

## 14 DESCRIPTIVE DOCUMENTS

### 14.1 Drawings

Refer to Certificate Annexe.

### 14.2 Associated Sira Reports and Certificate History

Issue	Date	Report No.	Comment
0	24 February 2009	R51L18616B	The release of the prime certificate.
1	26 August 2009	R51A20477A	The introduction of Variation 1, and the lusion of clause 17.4 applied in Report R51L18616B
2	13 September 2010	R20689B/00	The introduction of Variation 2.
3	24 September 2014	R70005417A	The introduction of Variation 3.
4	11 January 2016	R70052295A	The introduction of Variation 4.
5	15th October 2019	1448	<ul style="list-style-type: none"> <li>• Transfer of certificate Sira 08ATEX1266X from Sira Certification Service to CSA Group Netherlands B.V..</li> <li>• EC Type-Examination Certificate in accordance with 94/9/EC updated to EU Type-Examination Certificate in accordance with Directive 2014/34/EU. <i>(In accordance with Article 41 of Directive 2014/34/EU, EC Type-Examination Certificates referring to 94/9/EC that were in existence prior to the date of application of 2014/34/EU (20 April 2016) may be referenced as if they were issued in accordance with Directive 2014/34/EU. Variations to such EC Type-Examination Certificates may continue to bear the original certificate number issued prior to 20 April 2016.)</i></li> </ul>

## 15 SPECIAL CONDITIONS FOR SAFE USE (denoted by X after the certificate number)

15.1 The maximum constructional gap (ic) is less than that required by Table 2 of EN 60079-1:2007 clause 5.2.2 as detailed below:

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
Utrechtseweg 310,  
6812 AR, Arnhem Netherlands



## SCHEDULE

### EU-TYPE EXAMINATION CERTIFICATE

Sira 08ATEX1266X  
Issue 5

Flamepath	Maximum Gap (mm)	Comment
Push rod and main body	0.1	Cylindrical spigot joint

#### 16 ESSENTIAL HEALTH AND SAFETY REQUIREMENTS OF ANNEX II (EHSRs)

The relevant EHSRs that are not addressed by the standards listed in this certificate have been identified and individually assessed in the reports listed in Section 14.2.

# Certificate Annexe



**Certificate Number:** Sira 08ATEX1266X

**Equipment:** Valve Position Monitor

**Applicant:** Intex Controls Limited

## Issue 0

Drawing No.	Sheets	Rev.	Date	Description
A160147	1 of 1	E	18 Feb 09	Name plate
A190180	1 of 1	D	11 Dec 08	Design option/product nomenclature
C110130	1 of 1	B	27 Nov 08	Enclosure low cover
C110131	1 of 1	B	27 Nov 08	Enclosure high cover
C100150	1 of 1	C	04 Dec 08	Enclosure body
J100306	1 of 1	D	05 Dec 08	Shaft assembly
J100310	1 of 1	-	28 Sep 08	Typical internal clearances – short housing
J100311	1 of 1	-	29 Sep 08	Typical internal clearances – tall housing
J100305	1 of 1	B	27 Nov 08	General arrangement detail drawing
J100309	1 of 1	A	27 Nov 08	Free volume enclosure calculation drawings
407003	1 of 1	C	08 Dec 08	Shaft O-ring drawing
A170027	1 of 1	C	08 Dec 08	Shaft O-ring drawing
A170026	1 of 1	C	08 Dec 08	Housing O-ring drawing
407001	1 of 1	C	08 Dec 08	Housing O-ring drawing
A100353	1 of 1	-	22 Sep 08	External earth clamp

## Issue 1

Drawing No	Sheets	Rev.	Date	Description
J100323	1 of 1	-	01 Jun 09	VCT Module General Arrangement
A190180-X	1 of 1	E	01 Jun 09	Design Options/Product Nomenclature

## Issue 2

Drawing No	Sheets	Rev	Date (Sira stamp)	Title
A190180-X	1of1	F	06 Sep 10	Design Options/Product Nomenclature

## Issue 3

Drawing	Sheets	Rev.	Date (Sira stamp)	Title
A160147	1 of 1	G	24 Sep 17	Title Plate IECEx/ATEX Unit

## Issue 4

Drawing	Sheets	Rev.	Date (Sira stamp)	Description
C100150	1 of 1	E	08 Dec 15	Housing – Master Drawing
C110130	1 of 1	D	08 Dec 15	Small Cover
C110131	1 of 1	D	08 Dec 15	Tall Cover
A190180-X	1 of 1	H	08 Dec 15	Type IQ - Master Model Description

This certificate and its schedules may only be reproduced in its entirety and without change

**CSA Group Netherlands B.V.**  
Utrechtseweg 310,  
6812 AR, Arnhem,  
Netherlands